



CERTIFICATE OF ANALYSIS

W1110810

[]

. TIPPARAY PTY LTD
11 GRANDVIEW LANE
BOWEN MOUNTAIN NSW 2753

Lab Number: 60178035
Customer Reference Number: SAL 23658 Q
Site: SOURCE A

Sample Type: BORE WATER
Sample Notes:
Date and Time of Collection: 22/08/11, 1000
Date and Time of Testing: 23/08/11, 0700
Collected By: The Client
Tested: As Received

- 9 SEP 2011

TESTS

RESULTS

pH	4.8		
Conductivity	81	us/cm	
Sodium	14	mg/Litre	
Potassium	1.2	mg/Litre	
Calcium	0.3	mg/Litre	
Magnesium	2.5	mg/Litre	
Chloride	29	mg/Litre	
Nitrate	0.35	mg/Litre	
Sulphate	< 2	mg/Litre	(Not Detected)
Aluminium	< 0.1	mg/Litre	(Not Detected)
Lead	< 0.01	mg/Litre	(Not Detected)
Copper	0.03	mg/Litre	
Iron (total)	0.01	mg/Litre	

The above tests were performed at Sydney Analytical Laboratories who are NATA accredited (No 1884) for these tests.

The results are within the National Health and Medical Guidelines for Australian drinking water quality EXCEPT for pH. The limit of pH 6.5 to 8.5 is set to prevent rusting in water supply pipes, and to optimize the effectiveness of water supplies.
See enclosed fact sheet for pH.

Please see safe ranges and pH fact sheet.

Signed: *SK* Date: 06/09/11

*Sighted
a.g.*